

CERTIFICATE OF COMPLIANCE

Certificate Number 20170120-E475275
Report Reference E475275-20150616
Issue Date 2017-JANUARY-20

Issued to: Rotork Instruments Italy srl
via Portico 17
24050 Orio al Serio BG ITALY

**This is to certify that
representative samples of**

**OUTLET AND JUNCTION BOXES FOR USE IN
HAZARDOUS LOCATIONS**

Junction Box for use in Class I, Division 1, Groups A, B, C & D; and Class II Division 1, Groups E, F, and G Hazardous (Classified) Locations.

Models: JB000; followed by any single digit alpha numeric; followed by any single digit from 0 to 9 or any single letter from A to Z; followed by 11, 21, D1, or K1; followed by U; followed by 7 or 8; followed by 70; followed by 3, 4, 6, or 7; followed by 0; followed by 0; followed by any single digital alpha numeric.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:


UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations
CAN/CSA C22.2 No. 25-1966, Enclosures for Use in Class II Groups E, F, and G Hazardous Locations
CAN/CSA C22.2 No. 30-M1986, Rev. 1988-11, Explosion-Proof Enclosures for Use in Class I Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

